



## **FIRE AND EMERGENCY SERVICES**

### **FIRE ROUTE APPLICATION**

#### **TO: FIRE ROUTE APPLICANTS**

Enclosed is a fire route application package for the designation of the Fire Access Route as required in By-Law 93-93, as amended.

The application package consists of:

- An application form, which is to be completed in full and accompanied by a cheque in the amount of \$240.00 made payable to the City of Brampton for processing.
- The fee is waived if under Building Permit.
- Detailed installation guidelines
- A sample plan
- Information regarding disabled persons parking space requirements

#### **NOTE:**

- The plan may take the form of either a redaction of the previously approved site development plan or a redrawn facsimile. The plan is not required to be at any specific scale, however, a relative scale between site components must be maintained. Using the sample plan as a guide, the drawing is to indicate the building outline, principal entrances, hydrants, Siamese connections, fire access route, parking which abuts the fire route, municipal street and municipal address.

The complete application form, and processing fee are to be submitted to Fire and Emergency Services. The application will be reviewed, drawing number assigned and the location, type, and quantity of signage indicated on the plan.

The now completed official Fire Access Route Plan will be returned to the OWNER OF THE PROPERTY, so that the installation in conformance with this plan can begin.

Should any further information or assistance be required, please do not hesitate to contact this department at (905) 874-2740.

Please return completed application to:

Brampton Fire and Emergency Services  
Fire Prevention Division  
225 Central Park Drive,  
Brampton, ON L6S 6 H1

Downloaded from  
**Parking Sign**

The Corporation of the City of Brampton  
Designation of Fire Routes/By-law 93-93, As Amended

Applicant: \_\_\_\_\_

Address: \_\_\_\_\_

Person Making Application: \_\_\_\_\_

Contact: \_\_\_\_\_

Title: \_\_\_\_\_

Address: \_\_\_\_\_

Name of Owner: \_\_\_\_\_

Address: \_\_\_\_\_

Telephone: \_\_\_\_\_

Owner is: Individual ( ) Corporation ( ) Sole Proprietorship ( ) Partnership ( )

Type of Building for which application is being made: \_\_\_\_\_

Lot, Plan or Concession: \_\_\_\_\_

Address of Building: \_\_\_\_\_

Enclosed is my payment of \$240.00 which I understand is non-refundable.

\_\_\_\_\_  
Date

\_\_\_\_\_  
Signature

OFFICE USE ONLY

Approval Form to be completed by Brampton Fire & Emergency Services

Application # \_\_\_\_\_ Date of Receipt: \_\_\_\_\_

Fire Route designated as per attached plan.

Number of traffic signs required: \_\_\_\_\_ Signature: \_\_\_\_\_

Complete

FIRE ROUTE SIGNS ARE INSTALLED AS SHOWN ON THE ACCEPTED FIRE ROUTE PLAN

Date \_\_\_\_\_

## **FIRE ROUTES**

### **BY-LAW 93-93, SECTION 47**

#### **Following designation of fire routes by the Fire Chief and notice under the Fire Protection and Prevention Act 1997**

1. the owner of a property shall erect signs marking private roadways thereon as fire routes.
2. before erecting signs as required, the owner of property shall obtain direction from and the approval of the Fire Chief or the persons designated by him to give such direction and approval, for all such signs, the wording thereon and the locations thereof;
3. each private roadway which is located on a property of which the municipal address or location is listed in Schedule XX11 hereto and beside or near which there are signs marking it as a fire route is hereby designated as a fire route;
4. the owner of a property upon which there is a private roadway that has been designated as a fire route:
  - a. shall maintain the signs marking it as a fire route; and
  - b. shall keep such private roadway:
  - c. in good repair
  - d. clear of snow and ice
  - e. free of all obstructions

#### **Mounting and Placement of Fire Route Signs**

1. Fire route signs shall be mounted on permanent post, poles or building structure.
2. Fire route signs shall be erected at a height of between 1.9m (6 feet) and 2.5m (8 feet) as measured from the edge of the traveled portion of the designated route to the bottom edge of the sign.
3. Fire route signs shall be installed at a distance of between 0.3m (1 foot) and 3m (10 feet) from the traveled edge of the designated route.
4. Standard fire route signs as designated shall be installed along the route approximately 30 m (100 feet) intervals or as frequently as is necessary to identify the route in the judgment of the Fire Chief or his designate.

By-law number is not to be on a Fire Route sign

# Size and Type of Fire Route Signs Required

STANDARD SIGN SIZE TO BE 300MM X 450 MM (12" X 15")  
DESIGNATION  
ON DRIVEWAY  
BOTH SIDES  
THIS SIDE  
ON PRIVATE ROADWAY

Downloaded from  
Parking Sign

SAMPLE OF ACCEPTABLE SIGNS:



Downloaded from  
 Parking Sign

NOT TO SCALE

**LEGEND**

APPROXIMATE LOCATION OF PROPERTY LINE ————

FIRE ROUTE SHOWN AS ———

FIRE ROUTE SIGN ON STREETLIGHT POLE ———  BACK MOUNTED  
 END MOUNTED


FIRE ROUTE SIGN ON SIGN POST ———  BACK MOUNTED  
 END MOUNTED

FIRE ROUTE SIGN ON BUILDING OR STRUCTURE ———  BACK MOUNTED  
 END MOUNTED

ENTRANCE TO BUILDING ——— 

FIRE (SIAMESE) CONNECTION ——— 

FIRE HYDRANT ——— 



LOCATION / DESCRIPTION



DATE

SCHEDULE NUMBER